

Attestation

EU Taxonomy regulation

Emission of formaldehyde and carcinogenic compounds

On the 7th of June 2024, Eurofins Product Testing A/S received a sample of a SPC flooring with the product name:

SPC flooring

supplied by

Area Floors Zemin Kaplamalan San. Ve Tic. A.Ş.

The emissions were tested according to Regulation (EU) 2020/852 of the European Parliament and of the Council with regard to requirements for construction products on emission of formaldehyde and carcinogenic volatile organic compounds of section 7.1 (New buildings) and section 7.2 (Renovation of existing buildings).

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant EN 16516 (2020) testing standard (See test report no.392-2024-00175301_A_EN).

The emission result from the tested sample indicate that the product complies with the requirements of EU taxonomy regarding emission of formaldehyde and carcinogenic compounds.

Evaluation of the emission test result according to EU Taxonomy:

- The concentration of formaldehyde after 28 days was in compliance with the limit of $\leq 0.06 \text{ mg/m}^3$.
- Carcinogenic compounds were in compliance with the limit of 0.001 mg/m^3 .

11 April 2025



Claus Bonde
Analytical Service Manager



Rasmus Verdier
Analytical Service Manager